

October 2021

Day	Downtime	Availability	Daily Mwh	Rationale
1	0	100.00%	318	
2	0	100.00%	321	
3	0	100.00%	320	
4	0	100.00%	320	
5	0	100.00%	317	
6	0	100.00%	320	
7	0	100.00%	318	
8	0	100.00%	318	
9	0	100.00%	319	
10	0	100.00%	320	
11	0	100.00%	323	
12	0	100.00%	322	
13	0	100.00%	310	
14	0	100.00%	266	
15	0	100.00%	320	
16	0	100.00%	321	
17	0	100.00%	321	
18	0	100.00%	320	
19	0	100.00%	318	
20	0	100.00%	320	
21	0	100.00%	302	
22	0	100.00%	321	
23	0	100.00%	322	
24	0	100.00%	318	
25	0	100.00%	321	
26	0	100.00%	319	
27	4	83.33%	215	ACC Cooling Fan inverter trip on Lennox changeover
28	0	100.00%	321	
29	0	100.00%	318	
30	0	100.00%	308	
31	16	33.33%	96	Chain Conveyor 2 derailment due to TE bearing collapse & sprocket failure
Month	20	97.31%	9493	