

FORM WATER 2: Emissions to controlled water (W1) - Weekly samples

Permit Number : EPR/YP3930EX
Operator : Valero Energy Ltd
Installation Location : Pembroke Refinery, Pembroke, SA71 5SJ

Reporting Period : Q4 2021

Parameters: sulphides, fluoride, cyanide, suspended solids

Release Point	W1 discharge to Milford Haven Waterway		
	Daily ELV (mg/l)	3-month average of weekly results (mg/l)	Maximum weekly result (mg/l)
Sulphides	1	0.1	0.1
Fluoride	15	2	3
Cyanide	0.25	0.01	0.01
Suspended solids	85	17	40

Signed : *RDLivock*

Name : Richard Livock

On behalf of the Operator Valero Energy Ltd

Date : 12/01/2022
