Revision 01

Schedule 5 – Notification of Abnormal Emission Page 1 of 2

Part A – 609

Permit Number	**EPR/BL9941IC**
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Facility	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB
Time and date of the detection	During 24 hours on 12.04.19 to 14.04.19

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affect the environment

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken to stop any emission	
Description of the failure or accident	

(b) Notification requirement for a breach of a permit condition
To be notified immediately.


Emission point reference / source	W1		
Parameter(s)	Flow		
Limit	700 m3 / day		
Measured value and uncertainty	727 m3 12.04.19	761m3 13.04.19	710m3 14.04.19
Date and time of monitoring	During 24 hours on 12.04.19 to 14.04.19		
Measures taken, or intended to be taken, to stop the emission	Erratic increases in flow caused by volume surges from forward flow pump. Volume pumped inconsistent, so pump slowed down so that daily volume remains below 700m3.		

Time periods for notification following detection of a breach of a limit

Parameter	**Notification period**

(c) In the event of a breach of permit that poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:

Description of where the effect on the environment was detected	
Substance(s) detected	
Confirmation of substances detected	
Date of monitoring / sampling	

*** Name:**	Gwyn Jones
Post:	Quality Assurance Manager
Signature:	
Date:	15.04.19

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*

RF01

Revision 01

Schedule 5 – Notification of Abnormal Emission **Page 1 of 1**

Part B -609

Permit Number	**EPR/BL9941IC**
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB

Any more accurate information on the matters for modification under Part A	Monitor pump performance and volume.
Measurement taken, or intended to be taken, to prevent a recurrence of the incident	As above.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Continued monitoring.
* **Name:**	Gwyn Jones
Post:	Quality Assurance Manager
Signature:	
Date:	15.04.19

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*