

Consent no	NRWWIA151
------------	-----------

WATER INDUSTRY ACT 1991

SECTION 165 / 166

CONSENT TO DISCHARGE

TO: Dŵr Cymru Cyfyngedig
Pentwyn Road
Nelson
Treharris
Mid Glamorgan
CF46 6LY

The **NATURAL RESOURCES BODY FOR WALES** ("Natural Resources Wales") in pursuance of its powers under the Water Industry Act 1991 **HEREBY CONSENTS** to the making of a discharge as follows:

Raw Water

FROM: PLAS UCHAF RESERVOIR, NEAR LLANNEFYDD, LL16 5DY

AT: NATIONAL GRID REFERENCE SH 96772 71540

TO: UNNAMED TRIBUTARY OF THE AFON ELWY

SUBJECT TO: the conditions set out in the following schedule:

Raw Water

Schedule No. NRWWIA151

This consent is issued on the 21st day of March 2019
This consent takes effect on the 21st day of March 2019
This consent shall cease to have effect on the day of 1st October 2019

Signed: Emily Roe

CONSENT NO:	NRWWIA151
SCHEDULE NO:	NRWWIA151-01
DATE ISSUED:	21st March 2019

CONDITIONS OF CONSENT TO DISCHARGE RAW WATER (“the Discharge”)

NATURE OF THE DISCHARGE

1. The Discharge shall consist solely of raw water.

SOURCE OF THE DISCHARGE

2. The Discharge shall be derived from Plas Uchaf Reservoir.

LOCATION OF DISCHARGE

3. The location of the Discharge shall be at NGR SH 96772 71540, marked ‘Discharge Point’ on the site plan in Annex 1.

SAMPLE POINT

4. A sample point shall be provided and maintained so that a representative sample of the Discharge may be obtained.

VOLUME

5. The total daily volume of the Discharge shall not exceed 14,688 cubic metres.
6. The rate of the Discharge shall not exceed 170 litres per second.

COMPOSITION

7. The consent holder shall take all necessary steps to secure that any water discharged by it under this consent is as free as may be reasonably practicable from —
 - (a) mud and silt;
 - (b) solid, polluting, offensive or injurious substances;
and
 - (c) any substances prejudicial to fish or spawn, or to spawning beds or food of fish.

SCOURING

8. The rate of discharge shall be controlled to prevent any significant scouring of the bed or bankside of the receiving water.

CONSENT NO:	NRWWIA151
SCHEDULE NO:	NRWWIA151-01
DATE ISSUED:	21st March 2019

FLOODING


9. The discharge shall not cause or significantly contribute to flooding in the downstream catchment.

PERIOD OF DISCHARGE

10. The Discharge shall only be made between 21st day of March 2019 and the 1st day of October 2019.

CONSENT NO:	NRWWIA151
DATE ISSUED:	21st March 2019

ANNEX 1- PLAN No. NRWWIA151



CONSENT NO:	NRWWIA151
DATE ISSUED:	21st March 2019



© Crown Copyright and database right 2019. Ordnance Survey licence number 100019741.