


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_218
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	20 th November 2018		

Any more accurate information on the matters for notification under Part A.	As referenced on the Part A Notification
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>We would like to withdraw Part A Notification EP_EX_218 as the average result of the 3 runs was 9.5 mg/Nm³ and was below the ELV of 10 mg/Nm³. Testing performed 17/10/2018.</p> <p>The single run where the ELV was exceeded was performed starting 20 minutes after 2 hours downtime during which the oven was empty. The circulating air in zone 1 of the oven is hotter in these circumstances as there is no product there to take heat out. This might have resulted in more ammonia being released from the binder for a short time until the circulating air returned to normal operating temperature over about 40 minutes</p> <p>No further action is proposed at this time</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	25/04/2017, 23/05/17, 05/07/17, 14-15/08/17, 06/09/17, 14/09/17, 16-20/09/17, 26/09/17, 1-3/10/17, 9-11/10/17, 21/10/17, 23/10/17, 31/10/17, 08/12/17, 29/12/17, 09-11/01/18, 24/01/18, 26/03/18, 30/03/18, 17/04/18, 21/04/18, 26-27/04/18, 16/05/18, 11/7/18, 5/9/18, 7/9/18, 9/9/18, 10/9/18, 16/9/18, 15/10/18, 17/10/18, 19/10/18, 22/10/18, 3/11/18, 4/11/18

Name*	Graham Jones
Post	Process and Energy Manager
Signature	
Date	3rd May 2019

* authorised to sign on behalf of Knauf Insulation Ltd