


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_217
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	20 th November 2018		

Any more accurate information on the matters for notification under Part A.	As referenced on the Part A Notification. 54.9 mg/Nm ³ average of 3 runs.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>A request made on 20/11/18 for additional testing in Q4 was unsuccessful with Exova confirming there was no Q4 availability in a reply on 6/12/18.</p> <p>Operational checks were made on the impact jets on the extraction airflow. The jets were in good working order with good flow (280m³/h). The ceilcotes were also checked. Circulation flow pumps were all working OK and the pressure drops did not indicate any short circuiting of air or water flows in the ceilcote scrubbers.</p> <p>Particulate levels will be assessed again at the next scheduled test by Exova in Q2 2019</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	25/04/2017, 23/05/17, 05/07/17, 14-15/08/17, 06/09/17, 14/09/17, 16-20/09/17, 26/09/17, 1-3/10/17, 9-11/10/17, 21/10/17, 23/10/17, 31/10/17, 08/12/17, 29/12/17, 09-11/01/18, 24/01/18, 26/03/18, 30/03/18, 17/04/18, 21/04/18, 26-27/04/18, 16/05/18, 11/7/18, 5/9/18, 7/9/18, 9/9/18, 10/9/18, 16/9/18, 15/10/18, 17/10/18, 19/10/18, 22/10/18, 3/11/18, 4/11/18

Name*	Graham Jones
Post	Process and Energy Manager
Signature	
Date	7th May 2019

* authorised to sign on behalf of Knauf Insulation Ltd