

Permit Number: EPR/AB3094FQ

Operator:

Refresco Drinks UK Limited

Facility:

Wrexham Soft Drinks

Form Number:

Sewer 1 / 01/07/19

Reporting of emissions to sewer for the period from 01 Jan 2019 – 30 June 2019

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
S1	Total suspended solids	No limit set	Effluent is spot sampled hourly at site and Welsh Water test a composite sample every 2 months ¹	Low = 10 MG/L High = 136 MG/L Average = 32 MG/L	BS EN 872	Monthly	95%
S1	Effluent Flow (Sewer)	No limit set		83,275 Max m3	MCERTS self-monitoring of effluent flow scheme	Monthly	95%
S1	COD	No limit set		Low = 235 High = 7,510 Average = 2,209	BS EN 135006	Monthly	95%
S1	BOD	No limit set		N/A	BS EN 135006	Monthly	95%
S1	pH	No limit set		Low = 4.23 PH Units High = 11.79 PH units Average = 7.54 PH units	BS6068-2.50	Monthly	95%

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used, the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed



Date:.....

19/7/19