

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EP3034GS
Name of operator	Wynnstay
Location of Facility	Llysonnen Mill, Carmarthen
Time and date of the detection	14/03/22 10:58

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified Immediately	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a permit condition	
To be notified immediately	
Emission point reference/ source	W1
Parameter(s)	Total suspended solids
Limit	15 mg/l
Measured value and uncertainty	54 mg/l +/- 10 %
Date and time of monitoring	28/02/22 15:30
Measures taken, or intended to be taken, to stop the emission	- Hygiene Site hygiene is being prioritised, with an external road sweeper contracted to sweep all external areas every 2 weeks. The site is under new management and all cleaning and maintenance procedures are being reviewed. Additional full time cleaning staff have been employed commencing 14/03/22. - Drainage system. The site drainage system has been reviewed following unexpectedly low flow

	rates at discharge point W1. The size of the attenuation tank and the design and location of the hydrobrake are being investigated following instances of the hydrobrake blocking and the attenuation tank overflowing. A meeting has been arranged for 18/03/22 with an independent consultant to assess any modifications to the drainage system required. The reed bed is also to be assessed and additional reeds planted and refurbishment carried out if required.
--	--

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Sally Davies
Post	QC & Compliance Manager
Signature	<i>S. Davies</i>
Date	16/03/22

* authorised to sign on behalf of the Operator