



**Natural Solutions**  
(SW) Ltd  
2 - 4 Village Court,  
Village Farm Industrial  
Estate,  
Pyle, Bridgend,  
South Wales,  
CF33 6BX  
Tel: 01656 741799

**WPD CLYDACH DEPOT SITE  
DRAINAGE PLAN**  
DRAWN BY: WILLIAM BATTEN  
CHECKED BY: TIMOTHY WILLIAMS  
DATE: 28.05.2013  
VERSION: 2



- MH 1 6" Main run, 0.79m inv. 2 x 4" inlets
- MH 2 10" Main run, 1.17m inv. 2 x 6" inlets
- MH 3 6" Main run, 0.19m inv. 2 x 4" inlets
- MH 4 6" Main run, 0.25m inv. 1 x 6" inlets
- MH 5 6" Main run, 0.59m inv. 1 x 6" inlets
- MH 6 6" Main run, 0.94m inv. 1 x 8" inlet
- MH 7 9" Main run, 1.20m inv. 2 x 8" inlets
- MH 8 8" Main run, 0.94m inv. 1 x 6" inlet
- MH 9 6" Main run, 0.74m inv. 2 x 6" inlets
- MH 10 6" Main run, 0.69m inv. 1 x 6" inlets
- MH 11 10" Main run, 0.82m inv. 4 x 6" inlets
- MH 12 10" Main run, 1.35m inv. 3 x 6" inlets
- MH 13 Interceptor - Conder CNS15s/12
- MH 14 Campus Winkfilter
- MH 15 Soakaway

Storm water system, with flow direction

Foul water system, with flow direction

Presumed storm water system, with flow direction - further information obtained from previous site drainage plan supplied by the client

Presumed foul water system, with flow direction - further information obtained from previous site drainage plan supplied by the client

Storm water gully

Manhole with reference number

Roof water down pipe

Areas of potentially contaminative storage or use

Existing Control Measure

