

Compliance Report

Company:Harsco Environmental Contact:Paul Roberts

Authorisation number (s):Lancing Booth Stack Monitor

No exceedances

From:01 Jan 22 00:15:55 To:31 Mar 22 00:15:55

Device 1 : Stack1 Dust Cal Factor: 0.52 (constant) Average:1.050 Averaging Period:1 hrs

Emission Limit: 20.00 INDmg/m3

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
01 Jan 22	0.06	0	pass	pass
02 Jan 22	1.58	0	pass	pass
03 Jan 22	0.10	0	pass	pass
04 Jan 22	0.24	0	pass	pass
05 Jan 22	0.13	0	pass	pass
06 Jan 22	0.32	0	pass	pass
07 Jan 22	0.47	0	pass	pass
08 Jan 22	0.22	0	pass	pass
09 Jan 22	0.09	0	pass	pass
10 Jan 22	0.14	0	pass	pass
11 Jan 22	0.21	0	pass	pass
12 Jan 22	1.02	0	pass	pass
13 Jan 22	5.64	0	pass	pass
14 Jan 22	10.69	0	pass	pass
15 Jan 22	0.25	0	pass	pass
16 Jan 22	0.85	0	pass	pass
17 Jan 22	10.52	0	pass	pass
18 Jan 22	0.14	0	pass	pass
19 Jan 22	0.16	0	pass	pass
20 Jan 22	10.40	0	pass	pass
21 Jan 22	14.41	0	pass	pass
22 Jan 22	0.25	0	pass	pass
23 Jan 22	0.16	0	pass	pass
24 Jan 22	0.14	0	pass	pass
25 Jan 22	9.10	0	pass	pass
26 Jan 22	0.13	0	pass	pass
27 Jan 22	4.16	0	pass	pass
28 Jan 22	10.36	0	pass	pass
29 Jan 22	0.25	0	pass	pass
30 Jan 22	0.12	0	pass	pass
31 Jan 22	0.28	0	pass	pass
01 Feb 22	9.66	0	pass	pass
02 Feb 22	0.22	0	pass	pass
03 Feb 22	0.09	0	pass	pass
04 Feb 22	0.07	0	pass	pass
05 Feb 22	0.82	0	pass	pass
06 Feb 22	4.57	0	pass	pass
07 Feb 22	0.87	0	pass	pass
08 Feb 22	12.43	0	pass	pass
09 Feb 22	11.62	0	pass	pass
10 Feb 22	10.05	0	pass	pass
11 Feb 22	10.59	0	pass	pass
12 Feb 22	0.36	0	pass	pass
13 Feb 22	4.18	0	pass	pass
14 Feb 22	13.84	0	pass	pass
15 Feb 22	7.86	0	pass	pass
16 Feb 22	9.17	0	pass	pass
17 Feb 22	11.22	0	pass	pass
18 Feb 22	4.59	0	pass	pass
19 Feb 22	5.02	0	pass	pass
20 Feb 22	3.40	0	pass	pass
21 Feb 22	1.17	0	pass	pass
22 Feb 22	10.89	0	pass	pass
23 Feb 22	5.03	0	pass	pass
24 Feb 22	7.85	0	pass	pass
25 Feb 22	5.38	0	pass	pass
26 Feb 22	0.39	0	pass	pass
27 Feb 22	0.25	0	pass	pass
28 Feb 22	6.26	0	pass	pass
01 Mar 22	6.97	0	pass	pass
02 Mar 22	5.07	0	pass	pass
03 Mar 22	4.84	0	pass	pass
04 Mar 22	8.79	0	pass	pass
05 Mar 22	0.41	0	pass	pass
06 Mar 22	0.17	0	pass	pass
07 Mar 22	12.01	0	pass	pass
08 Mar 22	5.35	0	pass	pass
09 Mar 22	5.51	0	pass	pass
10 Mar 22	11.72	0	pass	pass
11 Mar 22	11.85	0	pass	pass
12 Mar 22	3.39	0	pass	pass

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
13 Mar 22	4.15	0	pass	pass
14 Mar 22	8.32	0	pass	pass
15 Mar 22	0.22	0	pass	pass
16 Mar 22	0.10	0	pass	pass
17 Mar 22	0.07	0	pass	pass
18 Mar 22	0.18	0	pass	pass
19 Mar 22	0.41	0	pass	pass
20 Mar 22	0.16	0	pass	pass
21 Mar 22	5.02	0	pass	pass
22 Mar 22	0.20	0	pass	pass
23 Mar 22	0.13	0	pass	pass
24 Mar 22	5.18	0	pass	pass
25 Mar 22	0.13	0	pass	pass
26 Mar 22	0.10	0	pass	pass
27 Mar 22	0.09	0	pass	pass
28 Mar 22	12.72	0	pass	pass
29 Mar 22	0.13	0	pass	pass
30 Mar 22	0.22	0	pass	pass
31 Mar 22	7.16	0	pass	pass