

Mar 2022

| Day | Downtime | Availability | Daily Mwh | Rationale |
|--------------|-------------|---------------|-------------|---|
| 1 | 2 | 91.67% | 293 | Start up Plant after Chain Conveyor 3 jam |
| 2 | 0 | 100.00% | 328 | |
| 3 | 0 | 100.00% | 327 | |
| 4 | 0 | 100.00% | 328 | |
| 5 | 9 | 62.50% | 204 | Plant bought offline after DCS lost communication with PLC. |
| 6 | 18.5 | 22.92% | 70 | |
| 7 | 0 | 100.00% | 271 | |
| 8 | 19.5 | 18.75% | 18 | Plant tripped due to Chain Conveyor 3 jam whilst Emergency dosing whilst repairing Buffer silo screw. Restart delayed due to waiting for boiler to refill and water chemistry prior to restart. |
| 9 | 14 | 41.67% | 129 | |
| 10 | 0 | 100.00% | 329 | |
| 11 | 0 | 100.00% | 328 | |
| 12 | 0 | 100.00% | 328 | |
| 13 | 0 | 100.00% | 329 | |
| 14 | 0 | 100.00% | 322 | |
| 15 | 0 | 100.00% | 327 | |
| 16 | 0 | 100.00% | 328 | |
| 17 | 0 | 100.00% | 329 | |
| 18 | 0 | 100.00% | 327 | |
| 19 | 0 | 100.00% | 322 | |
| 20 | 0 | 100.00% | 328 | |
| 21 | 0 | 100.00% | 326 | |
| 22 | 0 | 100.00% | 322 | |
| 23 | 0 | 100.00% | 323 | |
| 24 | 0 | 100.00% | 327 | |
| 25 | 0 | 100.00% | 326 | |
| 26 | 1 | 95.83% | 301 | Lost boiler O2 stability due to load shift and fuel feed blockage caused by disc screen drive chain failure and subsequent blockage. Plant restarted once resolved. |
| 27 | 7.5 | 68.75% | 214 | |
| 28 | 0 | 100.00% | 324 | |
| 29 | 0 | 100.00% | 324 | |
| 30 | 0 | 100.00% | 329 | |
| 31 | 0 | 100.00% | 330 | |
| Month | 71.5 | 90.39% | 9008 | |