

Variation notice with introductory note

Environmental Permitting (England & Wales) Regulations 2010

Old Barry Sidings

RR Davies Limited
Hopkinstown
Gyfellion Road
Pontypridd
Mid Glamorgan
CF37 2PP

Variation notice number
EPR/MP3894VQ/V002

Permit number
EPR/MP3894VQ

Old Barry Sidings

Permit number EPR/MP3894VQ

Introductory note

This introductory note does not form a part of the permit

The following notice, which is issued pursuant to regulation 20 and Part 1 of Schedule 5 of the Environmental Permitting (England and Wales) Regulations 2010 S.I.2010 No. 675 (the Regulations), gives notice of the variation of an environmental permit to operate a regulated facility.

Schedule 1 of this notice lists any deleted conditions, Schedule 2 lists any amended conditions, Schedule 3 lists any conditions that have been added and Schedule 4 shows any changes to the plan.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

Status Log of the permit		
Detail	Date	Response Date
WML Licence SY/05/94	09/02/1996	
Permit Modification	31/03/1999	
Full transfer of permit EPR/MP3894VQ/T001	ISSUE Date 07/10/2010	
Application EPR/ MP3894VQ/V002	Duly made 27/09/2010	
Additional Information Received	29/09/2010	29/09/2010
Variation issued	11/10/2010	

End of Introductory Note

Environmental Permitting
(England and Wales) Regulations 2010

Permit number

EPR/MP3894VQ

The Environment Agency in exercise of its powers under Regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 (SI 2010 No 675) varies the permit as set out below.

RR Davies Limited ("the operator"),

whose registered office is

**Bron-y-Garn Barn
Tonyrefial Road
Penycoedcae
Pontypridd
Rhondda Cynon Taff
CF37 1QA**

company registration number 05989319

holds a permit to operate a regulated facility at


**Old Barry Sidings
Hopkinstown
Gyfellion Road
Pontypridd
Mid Glamorgan
CF37 2PP**

and that permit is varied to the extent set out in Schedules 1 to 4 of this notice.

The notice shall take effect from 11/10/2010

Name Helen Smith

Date

	11 October 2010
---	-----------------

Authorised on behalf of the Environment Agency

Schedule 1 – conditions to be deleted

The following conditions are deleted

C14. No deposit of waste shall take place within 7 metres of the bank of any open water courses on the site unless such water courses have been diverted, culverted or otherwise protected in accordance with the working plan.

Schedule 2 – conditions to be amended

The following conditions are amended as follows

Schedule B Types of waste

Types of waste materials acceptable at the facility and the maximum quantities stored at any given time shall consist only of the following solid wastes:

Types of waste	Quantity
Vehicle bodies	200
Tyres	100
Batteries	200
Vehicle Components/ Engines	30 tonnes
Scrap Metal	75 tonnes
Waste oil	1200 litres
LP Gas Cylinders	5
TOTAL ANNUAL INPUT NOT TO EXCEED 25,000 TONNES	

Which do not contain any poisonous noxious or polluting substance or any bio- degradable wastes.

C19. Tanks or drums used for the storage of liquids shall be contained within bunded compounds. The containment capacity of the bund shall be at least 110% of the tank capacity in the case of a single tank. Where multiple tanks and drums are contained within a bund, then the bund capacity shall be either 110% of the capacity of the largest tank or drum, or 25% of the total volume of the liquid which could be stored in the bund, - which ever is the greater. The side walls and base of the bunded areas shall be lined with impervious material.

Every part of the storage tank shall be within the bund.

All taps or permanent valves through which liquid can be discharged shall be

1. Within the bund;
2. Discharged vertically downwards;
3. Shut and locked when not in use.

Where liquid from a tank is delivered through a flexible pipe permanently attached to the tank then –

- a) A tap valve shall be provided at the delivery end which automatically closes when not in use;
- b) An isolating valve shall be provided at the tank end of the flexible pipe which shall be kept locked when not in use;
- c) The flexible delivery pipe shall be kept within the bund when not in use.

Schedule 3 – conditions to be added

None.

Schedule 4 – amended plan

None.