

Permit Number: EPR/VP3736EF
Operator: The BOC Group Limited
Facility: Newport Steam Reforming Plant
Reporting: 4.2.2(a)

01/01/21 – 31/12/21

Reviewing the performance monitoring data for the installation for the given reporting period, the results are:

- Within the reporting limits for all parameters.

NOx emissions have remained in control at 82.9mgm^{-3} which is well within the limit value of 140mgm^{-3} .

S Roberts (Regional SHEQ Advisor South Wales)

25/01/2022