

Reporting of Emission to Surface Water for the period from 1st January 2021 to 30th June 2021.

Operator : RWE Generation UK plc

Form: Water1

Location: Aberthaw Quarry Ash Disposal Site

Permit/Variation Number: BP3339BH

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		<3.5 µg/l		28/04/2021	Sampling Amec/Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.0 µg/l				
	Boron, Dissolved		860 µg/l				
	Cadmium, Dissolved		0.08 µg/l				
	Calcium, Dissolved		260 mg/l				
	Chromium, Dissolved		11 µg/l				
	Copper, Dissolved		<4.0 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		41 mg/l				
	Manganese, Dissolved		14.0 µg/l				
	Molybdenum, Dissolved		1690 µg/l				
	Nickel, Dissolved		6.1 µg/l				
	Selenium Dissolved		n/s µg/l				
	Vanadium, Dissolved		2.8 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		129 mg/l				
	Electrical Conductivity at 20C		2480 mS/cm				
	Potassium, Dissolved		39 mg/l				
	Sodium, Dissolved		300 mg/l				
	Sulphate, Dissolved		515 mg/l				
	Total Oxidised Nitrogen		17 mg/l				
	Chloride		488 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		0.33 mg/l				
	Total Organic Carbon		5.3 mg/l				
	Nitrate		19.0 mg/l				
	pH		8.0 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		<3.5 µg/l		30/06/2021	Sampling Amec/Testing ALS	
	Antimony, Dissolved		<13 µg/l				
	Arsenic Dissolved		1.7 µg/l				
	Boron, Dissolved		1120 µg/l				
	Cadmium, Dissolved		0.37 µg/l				
	Calcium, Dissolved		300 mg/l				
	Chromium, Dissolved		9 µg/l				
	Copper, Dissolved		<4.0 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		45 mg/l				
	Manganese, Dissolved		1.4 µg/l				
	Molybdenum, Dissolved		2620 µg/l				
	Nickel, Dissolved		5.0 µg/l				
	Selenium Dissolved		n/s µg/l				
	Vanadium, Dissolved		3.1 µg/l				
	Mercury, Dissolved		0.02 µg/l				
	Total Alkalinity as CaCO3		73.40 mg/l				
	Electrical Conductivity at 20C		3220 mS/cm				
	Potassium, Dissolved		50 mg/l				
	Sodium, Dissolved		400 mg/l				
	Sulphate, Dissolved		668 mg/l				
	Total Oxidised Nitrogen		20 mg/l				
	Chloride		682 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		0.14 mg/l				
	Total Organic Carbon		5.9 mg/l				
	Nitrate		19.2 mg/l				
	pH		7.9 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		11 µg/l		02/02/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.5 µg/l				
	Boron, Dissolved	2000	770 µg/l				
	Cadmium, Dissolved	5	0.03 µg/l				
	Calcium, Dissolved		226 mg/l				
	Chromium, Dissolved	50	13 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		34 mg/l				
	Manganese, Dissolved		21.0 µg/l				
	Molybdenum, Dissolved		1700 µg/l				
	Nickel, Dissolved		8.1 µg/l				
	Selenium Dissolved		21 µg/l				
	Vanadium, Dissolved	60	5.3 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		2200 mS/cm				
	Potassium, Dissolved		34 mg/l				
	Sodium, Dissolved		250 mg/l				
	Sulphate, Dissolved	400	433 mg/l				
	Total Oxidised Nitrogen		21 mg/l				
	Chloride		404 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen	0.6	2.80 mg/l				
	Total Organic Carbon		1.8 mg/l				
	Nitrate		0.9 mg/l				
	pH	<9	8.0 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		<35 µg/l		01/03/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.4 µg/l				
	Boron, Dissolved	2000	1400 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		363 mg/l				
	Chromium, Dissolved	50	32 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<200 µg/l				
	Magnesium, Dissolved		47 mg/l				
	Manganese, Dissolved		33.0 µg/l				
	Molybdenum, Dissolved		3200 µg/l				
	Nickel, Dissolved		12.0 µg/l				
	Selenium Dissolved		44 µg/l				
	Vanadium, Dissolved	60	7.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		3430 mS/cm				
	Potassium, Dissolved		51 mg/l				
	Sodium, Dissolved		410 mg/l				
	Sulphate, Dissolved	400	664 mg/l				
	Total Oxidised Nitrogen		33 mg/l				
	Chloride		668 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	4.01 mg/l				
	Total Organic Carbon		2.0 mg/l				
	Nitrate		1.5 mg/l				
	pH	<9	8.1 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		10 µg/l		06/04/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.1 µg/l				
	Boron, Dissolved	2000	1300 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		391 mg/l				
	Chromium, Dissolved	50	28 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		25.00 µg/l				
	Magnesium, Dissolved		51 mg/l				
	Manganese, Dissolved		4.0 µg/l				
	Molybdenum, Dissolved		3800 µg/l				
	Nickel, Dissolved		12.0 µg/l				
	Selenium Dissolved		52 µg/l				
	Vanadium, Dissolved	60	9.2 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		3840 mS/cm				
	Potassium, Dissolved		55 mg/l				
	Sodium, Dissolved		480 mg/l				
	Sulphate, Dissolved	400	745 mg/l				
	Total Oxidised Nitrogen		36 mg/l				
	Chloride		789 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	2.21 mg/l				
	Total Organic Carbon		3.6 mg/l				
	Nitrate		1.3 mg/l				
	pH	<9	7.8 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		14 µg/l		06/05/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	4.0 µg/l				
	Boron, Dissolved	2000	1900 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		619 mg/l				
	Chromium, Dissolved	50	36 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		28.00 µg/l				
	Magnesium, Dissolved		63 mg/l				
	Manganese, Dissolved		1.8 µg/l				
	Molybdenum, Dissolved		5600 µg/l				
	Nickel, Dissolved		14.0 µg/l				
	Selenium Dissolved		71 µg/l				
	Vanadium, Dissolved	60	11.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		5520 mS/cm				
	Potassium, Dissolved		81 mg/l				
	Sodium, Dissolved		770 mg/l				
	Sulphate, Dissolved	400	1050 mg/l				
	Total Oxidised Nitrogen		46 mg/l				
	Chloride		1280 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	6.50 mg/l				
	Total Organic Carbon		2.7 mg/l				
	Nitrate		2.9 mg/l				
	pH	<9	8.0 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		<35 µg/l		03/06/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.3 µg/l				
	Boron, Dissolved	2000	1400 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		448 mg/l				
	Chromium, Dissolved	50	25 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		58 mg/l				
	Manganese, Dissolved		8.7 µg/l				
	Molybdenum, Dissolved		4400 µg/l				
	Nickel, Dissolved		13.0 µg/l				
	Selenium Dissolved		54 µg/l				
	Vanadium, Dissolved	60	9.5 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		4780 mS/cm				
	Potassium, Dissolved		75 mg/l				
	Sodium, Dissolved		680 mg/l				
	Sulphate, Dissolved	400	915 mg/l				
	Total Oxidised Nitrogen		39 mg/l				
	Chloride		1100 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	4.82 mg/l				
	Total Organic Carbon		4.0 mg/l				
	Nitrate		2.0 mg/l				
	pH	<9	8.1 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		12 µg/l		05/07/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.6 µg/l				
	Boron, Dissolved	2000	1700 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		493 mg/l				
	Chromium, Dissolved	50	22 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		59 mg/l				
	Manganese, Dissolved		1.2 µg/l				
	Molybdenum, Dissolved		4800 µg/l				
	Nickel, Dissolved		11.0 µg/l				
	Selenium Dissolved		41 µg/l				
	Vanadium, Dissolved	60	9.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		5290 mS/cm				
	Potassium, Dissolved		83 mg/l				
	Sodium, Dissolved		700 mg/l				
	Sulphate, Dissolved	400	987 mg/l				
	Total Oxidised Nitrogen		37 mg/l				
	Chloride		1260 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	4.52 mg/l				
	Total Organic Carbon		5.1 mg/l				
	Nitrate		2.6 mg/l				
	pH	<9	8.1 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		12 µg/l		02/02/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.0 µg/l				
	Boron, Dissolved		710 µg/l				
	Cadmium, Dissolved		0.03 µg/l				
	Calcium, Dissolved		224 mg/l				
	Chromium, Dissolved		10 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		33 mg/l				
	Manganese, Dissolved		21.0 µg/l				
	Molybdenum, Dissolved		1600 µg/l				
	Nickel, Dissolved		8.0 µg/l				
	Selenium Dissolved		18 µg/l				
	Vanadium, Dissolved		3.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		2090 mS/cm				
	Potassium, Dissolved		31 mg/l				
	Sodium, Dissolved		230 mg/l				
	Sulphate, Dissolved		401 mg/l				
	Total Oxidised Nitrogen		21 mg/l				
	Chloride		367 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		3.42 mg/l				
	Total Organic Carbon		1.6 mg/l				
	Nitrate		0.7 mg/l				
	pH		7.7 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		<35 µg/l		01/03/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.4 µg/l				
	Boron, Dissolved		1200 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		358 mg/l				
	Chromium, Dissolved		22 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<200 µg/l				
	Magnesium, Dissolved		42 mg/l				
	Manganese, Dissolved		40.0 µg/l				
	Molybdenum, Dissolved		3000 µg/l				
	Nickel, Dissolved		11.0 µg/l				
	Selenium Dissolved		40 µg/l				
	Vanadium, Dissolved		6.6 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		3580 mS/cm				
	Potassium, Dissolved		45 mg/l				
	Sodium, Dissolved		420 mg/l				
	Sulphate, Dissolved		603 mg/l				
	Total Oxidised Nitrogen		34 mg/l				
	Chloride		757 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		2.26 mg/l				
	Total Organic Carbon		1.2 mg/l				
	Nitrate		3.3 mg/l				
	pH		7.5 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		32 µg/l		06/04/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		3.9 µg/l				
	Boron, Dissolved		1600 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		500 mg/l				
	Chromium, Dissolved		39 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		59 mg/l				
	Manganese, Dissolved		67.0 µg/l				
	Molybdenum, Dissolved		5300 µg/l				
	Nickel, Dissolved		15.0 µg/l				
	Selenium Dissolved		71 µg/l				
	Vanadium, Dissolved		12.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		4920 mS/cm				
	Potassium, Dissolved		67 mg/l				
	Sodium, Dissolved		610 mg/l				
	Sulphate, Dissolved		959 mg/l				
	Total Oxidised Nitrogen		47 mg/l				
	Chloride		1070 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		9.53 mg/l				
	Total Organic Carbon		2.0 mg/l				
	Nitrate		2.2 mg/l				
	pH		7.0 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		41 µg/l		06/05/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		4.7 µg/l				
	Boron, Dissolved		2200 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		679 mg/l				
	Chromium, Dissolved		44 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		73 mg/l				
	Manganese, Dissolved		98.0 µg/l				
	Molybdenum, Dissolved		7000 µg/l				
	Nickel, Dissolved		17.0 µg/l				
	Selenium Dissolved		88 µg/l				
	Vanadium, Dissolved		14.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		5840 mS/cm				
	Potassium, Dissolved		87 mg/l				
	Sodium, Dissolved		830 mg/l				
	Sulphate, Dissolved		1190 mg/l				
	Total Oxidised Nitrogen		58 mg/l				
	Chloride		1320 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		15.10 mg/l				
	Total Organic Carbon		1.8 mg/l				
	Nitrate		2.8 mg/l				
	pH		7.7 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		30 µg/l		03/06/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		3.3 µg/l				
	Boron, Dissolved		1600 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		481 mg/l				
	Chromium, Dissolved		27 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		57 mg/l				
	Manganese, Dissolved		76.0 µg/l				
	Molybdenum, Dissolved		4800 µg/l				
	Nickel, Dissolved		13.0 µg/l				
	Selenium Dissolved		60 µg/l				
	Vanadium, Dissolved		10.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		4920 mS/cm				
	Potassium, Dissolved		75 mg/l				
	Sodium, Dissolved		680 mg/l				
	Sulphate, Dissolved		945 mg/l				
	Total Oxidised Nitrogen		45 mg/l				
	Chloride		1120 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		10.40 mg/l				
	Total Organic Carbon		1.6 mg/l				
	Nitrate		1.5 mg/l				
	pH		7.5 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		35 µg/l		05/07/2021	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		4.0 µg/l				
	Boron, Dissolved		2000 µg/l				
	Cadmium, Dissolved		<2 µg/l				
	Calcium, Dissolved		601 mg/l				
	Chromium, Dissolved		28 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		63 mg/l				
	Manganese, Dissolved		93.0 µg/l				
	Molybdenum, Dissolved		5900 µg/l				
	Nickel, Dissolved		14.0 µg/l				
	Selenium Dissolved		55 µg/l				
	Vanadium, Dissolved		12.0 µg/l				
	Mercury, Dissolved		0.00 µg/l				
	Total Alkalinity as CaCO3		<2.8 mg/l				
	Electrical Conductivity at 20C		6360 mS/cm				
	Potassium, Dissolved		97 mg/l				
	Sodium, Dissolved		840 mg/l				
	Sulphate, Dissolved		1140 mg/l				
	Total Oxidised Nitrogen		46 mg/l				
	Chloride		1530 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		18.90 mg/l				
	Total Organic Carbon		1.3 mg/l				
	Nitrate		1.7 mg/l				
	pH		7.6 pH Units				

[1] The result given is the maximum value (or the minimum value in the case of a limit that is fdpressed as a minimum) obtained during the reporting period, fdpressed in the same terms as the

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
----------------	-------------------------	-------------------------	-----------------------	-------------------------------	---	--	-------------------------------

[6] The emission limit values for all substances is fdpressed as a maximum individual value, unless otherwise stated.

S. Camps

Signed Date
(authorised to sign as representative of the Operator)

17/09/2021 (Reissued 26/01/2022)