

OPERATIONAL PARAMETERS

SUMMARY FOR **QUARTER 1 – 01 JAN 2022 to 31 MAR 2022.**

Operator: Dragon LNG

Location: Waterston, Milford Haven, SA73 1DR

Authorisation/Variation Number: EA/EPR/AP3136UA/V004

Parameter – Effluent discharge

Parameter		1Spot Sample			Limit
		Jan 2022	Feb 2022	Mar 2022	
⁽¹⁾ E2 A Purge water	Oil (mg/l)	No Flow	No Flow	No Flow	5
	Suspended Solids (mg/l)	No Flow	No Flow	No Flow	50
	pH	No Flow	No Flow	No Flow	6 - 9
⁽¹⁾ E2 B Effluent water	Oil (mg/l)	No Flow	No Flow	No Flow	5
	Suspended Solids (mg/l)	No Flow	No Flow	No Flow	50
	pH	No Flow	No Flow	No Flow	6 - 9
⁽¹⁾ E3 Overflow from firewater reservoir	Oil (mg/l)	<1	<1	<1	5
	Suspended Solids (mg/l)	<2	<2	<2	50
	pH	7.4	7.6	8	6 - 9
	Total Flow (m³)	2851.59	2948.86	2145.48	
	⁽²⁾ TON (mg/l as N)	8.80	9.62	9.64	45
	TON (kg / month)	25.10	28.39	20.70	

Notes

- 1) Values reported in above table for Oil, pH & SS are average values for the month from a series of weekly spot samples. **Zero (0)** notifications of individual breaches have been necessary during Q4 as the individual spot sample results **have not** been in breach of permit limits.
- 2) TON calculated from online continuous analyser that measures Nitrates & Nitrites concentrations (mg/l as N) directly and reports average values for the month.

Signed on behalf of the Operator by

Name: **Priscilla Wilson**

Designation: **HSE Lead**

Date: 26/04/2022