

Permit Number: EPR/BL3986ID

Operator: Tarmac Cement and Lime Ltd

Installation: Aberthaw Works

Form number: Air 10 / 31 August 2010

Reporting of non-kiln operational summary of continuous measurements for the month November 2021

Pollutant	Release point	Daily average limit mg/m3	Maximum daily average mg/m3	Average of daily averages mg/m3
Particulate matter	A2	20	6.53	4.51
	A3	20	2.26	1.69

Operator's comments:

Signed: Paul Firth, EmissionMonitoring Technician (via paul.firth@tarmac.com)
(authorised to sign as representative of Tarmac Cement and Lime Ltd)

Date: 02/12/2021