

IQE Silicon Compounds Ltd

RELEASE TO SEWERS

Release Summary for 6 months ending 31/12/21

Operator: IQE Silicon Compounds Ltd

Permit Number: BJ6968IY

Location: St. Mellons

Release Points **S1**

Release points shall be sampled once every six months, and results submitted on a six-month basis

Parameter		
	Suspended Solids mg/l	pH
Maximum	5	9.0
Minimum	5	9
Average	5.00	9.00

Limits: Suspended Solids 400mg/l

pH: between 6 and 11

Signed on behalf of Operator:



Dated: 14/01/2022

Form S1 (Version date 30/04/01)