

Permit number: EPR/SP3537VQ

Operator:

Biogen (Bryn Pica) Limited

Facility: Bryn Pica Anaerobic Digestion Site

Form Number

Performance1 / 13/05/2015

Reporting of other performance indicators for the year 2020 from 01/01/2020 to 31/12/2020

Parameter	Units
Power output – Electricity	9670.4 MWh
Energy efficiency	0.0029 MWh/m ³ biogas
Electrical energy exported to the grid	8889.1 MWh (Electricity Meter)
Electrical energy drawn from the grid	225.0 MWh
Water usage	464 m ³
Operational time of emergency flare	3.46% of operational time
Amount of biogas combusted in the CHP unit per day	9,075.4 m ³ /day
Operator's comments: *The figures provided refer to imported electricity. Parasitic energy ie energy produced and consumed by site in 2020 was 216.6 MWh	

Signed  Date.....28 – 01- 2021.....
 (Authorised to sign as representative of Operator)

Permit Number
EPR/SP3537VQ