

FORM WATER 1b: Emissions to controlled water (W1) – Weekly and quarterly samples

Permit Number: EPR/KP3036AX

Operator: Puma Energy (UK) Limited

Installation Location: Milford Haven Terminal, Milford Haven, SA73 3JD

Q1 2022

Parameters: COD, Cyanides, Suspended Solids

Release Point	W1 discharge from effluent treatment plant		
Parameter	ELV (mg/l)	3-month average of weekly results (mg/l)	Maximum weekly result (mg/l)
COD	200	51	73
Sulphides	1	0.1	0.1
Suspended Solids	45	11	19

Parameters: Copper, Nickel, Iron, Zinc, Arsenic, Chromium, Lead, Mercury, Cadmium

Release Point	W1 discharge from effluent treatment plant		
Parameter	ELV (µg/l)	3-month average of quarterly results (µg/l)	Maximum result (µg/l)
Copper	220	1.0	1.0
Nickel	120	6.59	6.59
Iron	4000	610	610
Zinc	85	12.2	12.2
Arsenic	-	<2	<2
Chromium	-	5.4	5.4
Lead	-	<1	<1
Mercury	2.4	<0.02	<0.02
Cadmium	8	5.4	5.4

Signed

Sarah Jones

Name Sarah Jones

On behalf of the Operator Puma Energy (UK) Limited

Date 01/04/2022